



The Board of Education of School District No. 83 (North Okanagan-Shuswap)

341 Shuswap Street SW, Box 129, Salmon Arm, BC, V1E 4N2

Phone: (250) 832 2157 Fax: (250) 832 9428

W/O #	OPEN DATE	REQUEST	WRK TYPE	ROOM
77473	9/3/2019	HEATING - BOILER & HOT WATER TANK TEMPERATURE & PRESSURE RELIEF VALVE TRIP TESTING & INSPECTION - ANNUAL PM	PM	
77516	9/3/2019	HEATING - BOILER SYSTEM CHECK & PUMP MAINTENANCE - ANNUAL NOVEMBER PM	PM	
78109	9/23/2019	REPLACE PLUGS AND COVERS IN NEWLY PAINTED AREAS	RM	HALLWAYS
78392	9/30/2019	ELECTRICAL - EMERGENCY - PROPANE SENSOR TESTING - YEARLY PM	PM	
78446	9/30/2019	HEATING - EXPANSION TANK SERVICE - SEMI ANNUAL PM	PM	
78464	9/30/2019	HVAC - CO2 SENSOR CALIBRATION AND SET UP - ANNUAL PM	PM	
78351	9/30/2019	BUILDING- SITE - PLAYGROUND EQUIPMENT INSPECTION & MINOR REPAIR - SEMI ANNUAL PM	PM	
78584	10/3/2019	**2019- 2020 SNOW REMOVAL DO NOT CLOSE**	RM	
79053	10/28/2019	CARPENTRY REPLACE WORN FLOOR TILES IN ADMIN OFFICE AND MAIN OFFICE.	RM	OFFICE
079090-11	10/29/2019	REPLACE FURNACES IN GYM STORAGE ROOM	BP	
79142	10/29/2019	BUILDING - SITE - SNOW PLOWING AND ICE CONTROL - ANNUAL PM	PM	
79166	10/29/2019	BUILDING - SITE - LEAF CLEANUP - ANNUAL PM	PM	
79203	10/29/2019	HEATING - BOILER SYSTEM CHECK & PUMP MAINTENANCE - ANNUAL NOVEMBER PM	PM	

79805	11/21/2019	BOY'S URINAL IN THE POD IS NOT AUTO FLUSHING, NEEDS BATTERY?	RM	BOY'S WASHROOM
79822	11/22/2019	REPAIR FLOOR BY FIRE DOORS - AS PER FACILITY TOUR (see mel remarks)	RM	
80000	11/28/2019	BUILDINGS - WASHROOM INSPECTION AND MINOR REPAIRS - YEARLY PM	PM	
80028	11/28/2019	HEATING - BOILER COMBUSTION ANALYSIS & TESTING (PULSE TYPE) - ANNUAL PM	PM	
80670	1/6/2020	HEATING - ROOM #14 HEATER IN COAT ROOM - EXCESSIVE HEAT - FAN DOESN'T SEEM TO BE TURNING ON. SMELLS LIKE "CRAYON" SEE CHIEF CUSTODIAN	RM	
80740	1/8/2020	PLUMBING - SINK IN STRONG START ROOM NOT DRAINING - CHIEF CUSTODIAN CAN NOT GET IT TO DRAIN PROPERLY	RM	
80789	1/10/2020	NEED WORK ORDER TO REPLACE THE BOILER GAS REGULATORS. WE HAVE THE PARTS ALREADY.	BD	BOILER RM.
80864	1/14/2020	GROUNDS A TRE BRANCH IS BROKEN AND HANGING IN A DANGEROUS POSITION IN THE PARKVIEW FOREST. PLEASE REMOVE BRANCH.	RM	
80989	1/20/2020	DUCT CLEANING FOR OFFICE AREA	RM	
80993	1/20/2020	HEATING - COUNSELLOR'S OFFICE IS VERY HOT - PLEASE CHECK	RM	
81060	1/23/2020	ROOF LEAKING INTO CLASSROOM #14 - PUDDLE ON FLOOR AND BOOKS DAMAGED - CALLED OPERATIONS	INS	
81187	1/29/2020	HAULING - PLEASE HAUL CHALKBOARD ON WHEELS (IN HALL OUTSIDE OF LRT ROOM)	DEL	
081060-14	1/29/2020	ROOF LEAKING INTO CLASSROOM #14 - PUDDLE ON FLOOR AND BOOKS DAMAGED - CALLED OPERATIONS	INS	